

Datum	Zulauf Menge m³/d	Zulauf BSB5 mg/l	Zulauf CSB mg/l	Zulauf NH4-N mg/l	Zulauf NO3-N mg/l	Zulauf GesN TN mg/l	Zulauf Pges mg/l	Fracht Nges. kg/d	Fracht BSB5/d kg/d	Fracht CSB/d kg/d	Ablauf		Bemerkung
											Monat	mittl./max mg/l	
05.05.2021	3652	720	1134						2629	4141		BSB5 3/CSB 17	
12.05.2021	2614	740	856						1934	2238		BSB5 5/CSB 27	
19.05.2021	3296	480	735						1582	2423		BSB5 4/CSB 14	
26.05.2021	3815	720	1057						2747	4032		BSB5 6/CSB 22	
05.01.2021	4377	540	820						2364	3589		BSB5 3/CSB 24	
13.01.2021	3424	620	933						2123	3195		BSB5 3/CSB 24	
20.01.2021	3642	700	981						2549	3589		BSB5 4/CSB 28	
26.01.2021	2923	680	1010						1988	2952		BSB5 4/CSB 34	
09.01.2020	3628	620	968						2249	3512		BSB5 4/CSB 26	
15.01.2020	3643	640	1014						2332	3694		BSB5 5/CSB 36	
21.01.2020	3100	600	944						1860	2926		BSB5 4/CSB 32	
28.01.2020	2399	580	756						1391	1814		BSB5 5/CSB 38	

Datum	Zulauf	Zulauf	Zulauf	Zulauf	Zulauf	Zulauf	Zulauf	Fracht	Fracht	Fracht	Ablauf	Bemerkung
	Menge m³/d	BSB5 mg/l	CSB mg/l	NH4-N mg/l	NO3-N mg/l	GesN TN mg/l	Pges mg/l	Nges. kg/d	BSB5/d kg/d	CSB/d kg/d	mittl./max Monat mg/l	
04.02.2021	4068	560	855						2278	3478	BSB5 3/CSB 22	
11.02.2021	3797	880	1282						3341	4868	BSB5 8/CSB 62	
15.02.2021	3042										CSB 31	Analyse
18.02.2021	2860	740	1195						2116	3417	BSB5 3/CSB 28	
24.02.2021	3334	660	1040						2200	3467	BSB5 3/CSB 24	
05.02.2020	3760	640	967						2406	3636	BSB5 3/CSB 28	
11.02.2020	3587	380	594						1363	2131	BSB5 3/CSB 25	
20.02.2020	3527	580	935						2046	3298	BSB5 4/CSB 37	
27.02.2020	2180	660	989						1439	2156	BSB5 3/CSB 27	
05.08.2020	1905	680	946						1295	1802	BSB5 4/CSB 33	
12.08.2020	3192	460	685						1468	2187	BSB5 3/CSB 25	
20.08.2020	3113	460	644						1432	2005	BSB5 3/CSB 24	
26.08.2020	2824	660	711						1864	2008	BSB5 3/CSB 21	

Datum	Zulauf	Zulauf	Zulauf	Zulauf	Zulauf	Zulauf	Zulauf	Fracht	Fracht	Fracht	Ablauf	Bemerkung	
	Menge m³/d	BSB5 mg/l	CSB mg/l	NH4-N mg/l	NO3-N mg/l	GesN TN mg/l	Pges mg/l	Nges. kg/d	BSB5/d kg/d	CSB/d kg/d	mittl./max Monat mg/l		
08.04.2021	3187	560	869						1785	2770	BSB5 3/CSB 22		
15.04.2021	2599	640	967						1663	2513	BSB5 3/CSB 22		
21.04.2021	3040	360	587						1094	1785	BSB5 7/CSB 34		
29.04.2021	2343	460	671						1078	1572	BSB5 8/CSB 50		
03.03.2021	3145	940	1122						2956	3529	BSB5 6/CSB 41		
11.03.2021	3079	620	947						1909	2916	BSB5 4/CSB 42		
16.03.2021	2276	820	1123						1866	2556	BSB5 4/CSB 41		
24.03.2021	2132	600	980						1279	2217	BSB5 5/CSB 35		
Höchstwert	4377	940	1282	5,00	60,00	70,00	6,00	250	3341	4868	BSB5 8/CSB 62		
< 85 %	3587	740	1040						2629	3636	BSB5 8/CSB 41		
<b>Auswertung</b>	<b>Betriebsprotokolle</b>		<b>Jahre 2020 u. 2021</b>									Überschreitung	
	<b>Leistungsermittlung</b>											Bemessung "Neu"	
	<b>zus. 8 Monate mit wöchentlicher Probenahme und Analysen an insgesamt 32 Tagen</b>												