

Monat Jahr	Zulauf														Ablauf			
	Menge		Temp.		BSB5		CSB		CSB/ BSB5	NH4-N	NO3-N	GesN	Pges	CSB		GesN TN	Pges	
	mittl. m3/d	max m3/d	mittl. °C	max °C	mittl. mg/l	max mg/l	mittl. mg/l	max mg/l	mittl.	max mg/l	max mg/l	max mg/l	max mg/l	mittl. mg/l	max mg/l	max mg/l	max mg/l	
<b>Mai 21</b>	2435	3815	23	26	665	740	946	1134	<b>1,42</b>	3,0	37,0	<b>62,0</b>	<b>4,8</b>	20	27	2,49	0,611	
<b>April 21</b>	2270	4169	24	26	505	640	774	967	<b>1,53</b>	1,6	35,5	<b>48,3</b>	<b>5,2</b>	34	50	4,67	0,675	
<b>März 21</b>	2623	3635	22	24	745	940	1043	1123	<b>1,40</b>	1,7	48,0	<b>80,0</b>	<b>4,7</b>	40	42	0,24	0,844	
<b>Februar 21</b>	3141	4996	22	25	710	880	1089	1282	<b>1,53</b>	1,8	41,5	<b>61,2</b>	<b>5,1</b>	33	62	0,51	0,316	
<b>Januar 21</b>	2639	4800	21	24	635	700	936	1010	<b>1,47</b>	1,9	41,1	<b>59,3</b>	<b>5,0</b>	28	34	0,69	0,302	
<b>Dezember 20</b>	1900	3832	21	25	667	680	942	978	<b>1,41</b>	2,3	38,7	<b>55,2</b>	<b>5,1</b>	26	30	0,73	0,359	
<b>November 20</b>	2548	3581	24	26	600	620	936	985	<b>1,56</b>	1,9	43,3	<b>57,3</b>	<b>5,1</b>	28	36	0,77	0,396	
<b>Oktober 20</b>	2604	4112	24	27	545	700	814	1089	<b>1,49</b>	1,8	38,0	<b>64,0</b>	<b>4,3</b>	22	24	0,35	0,911	
<b>September 20</b>	2429	4103	25	27	650	800	904	1189	<b>1,39</b>	2,0	40,3	<b>55,1</b>	<b>5,5</b>	22	25	1,87	0,568	
<b>August 20</b>	2289	3490	26	29	565	680	746	946	<b>1,32</b>	2,4	30,0	<b>42,7</b>	<b>5,1</b>	26	33	2,80	0,368	
<b>Juli 20</b>	2279	4309	20	28	600	680	878	989	<b>1,46</b>	2,0	30,2	<b>51,7</b>	<b>5,2</b>	20	23	2,70	0,471	
<b>Übersicht</b>	<b>Monatsauswertung Mittel- und Maxwerte zus. 11 Monate</b>										<b>max. Zulaufkonzentrationen Auslegungsgrundlage für NH4-N, NO3-N, GesN, Pges</b>							